



Product Service

CERTIFICATE

No. B 085127 0011 Rev. 00

Holder of Certificate: **Wuxi Betteri Electronic Technology Co., LTD**
5-1, #11, Jinshan Rd. Branch#IV
Wuxi Optoelectronic Material
Science&Technology Park
214037 Wuxi
PEOPLE'S REPUBLIC OF CHINA

Certification Mark:



Product:

Connector

Installation Couplers for use on AC side of Photovoltaic Sys-tems

Model(s):

BC01-3M22-15(Male)& BC01-3F22-15(Female)
BC01-3M22-05(Male)& BC01-3F22-15(Female)

Parameters:

Rated Voltage: 250VAC
Rated Current: 20A(2.5mm²),25A(4mm²)
Overvoltage Category: III
Application Class: A
Protection Class: II
Degree of Protection: IP68 (1m, 1h)
Rated Impulse Voltage: 4kV
Poles configuration: 1P+N+PE

Tested according to: PPP 59015A:2013

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition, the certification holder must not transfer the certificate to third parties. This certificate is valid until the listed date, unless it is cancelled earlier. All applicable requirements of the testing and certification regulations of TÜV SÜD Group have to be complied. For details see: www.tuvsud.com/ps-cert

Test report no.: 704071507102-01
Valid until: 2026-02-03

Date, 2021-02-04

(Yaqun Alex Liu)